



# Certificate of Compliance

**Certificate:** 1701489 (LR 104031)

**Master Contract:** 182407

**Project:** 2328691

**Date Issued:** September 3, 2010

**Issued to:** **Hummel AG**  
**Lise-Meitner-Straße 2**  
**Denzlingen, 79211**  
**Germany**  
**Attention: Fritz Zuegel**

*The products listed below are eligible to bear the CSA Mark shown*



*Johann Borabon*

**Issued by:** Johann Borabon

## **PRODUCTS**

**CLASS 6233 02** - RECEPTACLES - Special Use Connectors

Special-use M23, Series 75XX, 76XX male and female connectors, 6-Poles (6) 2.0mm contacts; 8-Poles (4) 2.0mm contacts and (4) 1.0mm contacts; 2.0mm contacts rated 17A max (Nos 12-18 AWG), 1.0mm contacts rated 7A max (Nos 18-24 AWG), 600V.

Notes:

1. Devices are intended for disconnecting use only and not for interrupting current.
2. Supplied only to manufacturers, as components, for the assembly of Certified electrical equipment, where the acceptability of the combination is to be determined in the end use.
3. The letters "XX" in the Series are replaced by alphanumeric characters.
4. Suffixes are added to the Series designations.

## **APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 182.3-M1987 - Special Use Attachment Plugs, Receptacles, and Connectors